

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-0694:170 Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02451-1133
Contact: Anthony J. Shalna (781) 471-3000*

DESIGN: Models PSD-7155 and PSD-7156 photoelectric type smoke detectors. Refer to listee's data sheet (9020-0304/12-92) for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a photoelectric smoke detector for use with 2-WB, 2WRLT, 2WRB, 4WRB or MA001 bases (CSFM Listing No. 7300-0694:171) and separately listed compatible fire alarm control units. Suitable for duct applications having air velocity of 500-4000 fpm when using Models 2WRLT, 2WRB or 4WRB bases. Suitable for releasing device service when using Models 2WRB or 4WRB bases.

XLF: 7272-1076:117

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 21, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager